



eA796916

Mr Hugh Phillips
Project Manager
T & J Contructions
PO Box 259
Enfield Plaza SA 5085

Public Health

Citi Centre Building
11 Hindmarsh Square
Adelaide SA 5000

PO Box 6, Rundle Mall
Adelaide SA 5000
DX 243

Tel (08) 8226 7100

Fax (08) 8226 7102

www.health.sa.gov.au

Dear Mr Phillips

RE: APPROVAL FOR CARTING OF RECYCLED WATER

Pursuant to the Public and Environmental Health Act and Regulations approval has been granted for carting of water from the Glenelg to Adelaide Recycled Water Scheme (GARWS), Mawson Lakes and the Southern Urban Recycled Scheme (SURS). The recycled water can be used for irrigation of gardens, lawn areas, landscape areas and plants, vehicle washing, dust suppression and supply to secondary storage in accord with the following conditions:

1. The water is to be transported in a dedicated vehicle or vessel. The vehicle/vessel cannot be used for carting lower quality recycled water, water for drinking or hazardous chemicals. The vehicle/vessel should be marked to indicate that the contents are not suitable for drinking.
2. In areas served by an SA Water supply, carted water can only be supplied to secondary storages and permanent irrigation systems if the system has been inspected and approved by SA Water.
3. If water is applied directly from the vessel to irrigate gardens, lawn areas, landscape areas or plants it should not be allowed to run-off off the site and ponding should be avoided
4. Water should only be taken with permission by SA Water and from a nominated off take.
5. A log book is to be maintained recording the:
 - date of delivery to a recipient/customer
 - volume delivered
 - intended use of the water
 - name and address of the recipient/customer
6. Recipients/customers should be advised that the water is not suitable for drinking, for use inside homes or to fill swimming pools or spas.
7. Employees and contractors using recycled water are to be instructed in appropriate health and safety procedures pursuant to Occupational Health, Safety and Welfare requirements. This should include that the water is not suitable for drinking.
8. Non-compliance with any of the conditions for approval should be rectified immediately and should be reported to the Department for Health and Ageing.

9. The Department for Health and Ageing reserves the right to revoke or alter approval conditions if recycled water is used in a manner that is prejudicial to public and environmental health or raises environmental nuisance.

Approved by

Date 10 MAY 2013



Dr David Cunliffe

Principal Water Quality Advisor

Scientific Services – Public Health

Delegate of the Minister for Health and Ageing, pursuant to the Public and Environmental Health (Waste Control) Regulations

NOTE 1: The approval issued does not alleviate responsibilities for obtaining relevant approvals, permits or licenses under other Acts or Regulations.